



SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUARTERS, MUGLISARA,
SURAT - 395003

Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

To,
The Principal,
Kendriya Vidyalaya No.1,
Ichhanath Surat.

Sub: - Fire Fighting System in Kendriya Vidyalaya No.1, Ichhanath, Surat.

Ref: - Your Letter dated :-30/ 10/2018

Sir,

With reference to the above Fire Fighting System installed in Kendriya Vidyalaya No. 1, Ichhanath, Surat. was inspected by this on dated :- 30/10/2018

During inspection of the said premises, following systems were found adequate and in working condition.

1	Dry Chem. Powder Fire Extinguishers.	5Kg Capacity	07 Nos
2	Carbon Dioxide Fire Extinguishers	2 Kg Capacity	05 Nos
3	Fire Buckets filled with water /sand		12 Nos
4	Under Ground Water Tank Capacity		30,000 ltrs
5	Over Head Water Tank Capacity		5,000Ltrs
6	EXIT marking as required		Yes

You are hereby advised to maintain the above system in good working condition.

The administrative charge of Rs.500/- has been recovered vide receipt no- 161/ 5 dated - 30- 10-2018

The duration of the inspection report is valid up to (one year from the date of issue.)

FES/NOC/OUTWARD/ 1318
DT. 30 - 10 -2018



30/10/2018
I/C CHIEF FIRE OFFICER
Surat Municipal corporation